

Affirmative Action
(231)724-6703
FAX (231)722-1214

Assessor/
Equalization Co.
(231)724-6386
FAX (231)724-1129

Cemetery/Forestry
(231)724-6783
FAX (231)724-4188

City Manager
(231)724-6724
FAX (231)722-1214

Clerk
(231)724-6705
FAX (231)724-4178

Comm. & Neigh.
Services
(231)724-6717
FAX (231)726-2501

Computer Info.
Technology
(231)724-4126
FAX (231)722-4301

Engineering
(231)724-6707
FAX (231)727-6904

Finance
(231)724-6713
FAX (231)726-2325

Fire Department
(231)724-6795
FAX (231)724-6985

Human Resources
Co. (Civil Service)
(231)724-6442
FAX (231)724-6840

Income Tax
(231)724-6770
FAX (231)724-6768

Mayor's Office
(231)724-6701
FAX (231)722-1214

Planning/Zoning
(231)724-6702
FAX (231)724-6790

Police Department
(231)724-6750
FAX (231)722-5140

Public Works
(231)724-4100
FAX (231)722-4188

SafeBuilt
(Inspections)
(231)724-6715
FAX (231)728-4371

Treasurer
(231)724-6720
FAX (231)724-6768

Water Billing
(231)724-6718
FAX (231)724-6768

Water Filtration
(231)724-4106
FAX (231)755-5290

MUSKEGON



West Michigan's Shoreline City
www.shorelinecity.com

July 28th, 2021

LAKETON AVENUE TRAIL LIGHTING – RFP

ADDENDUM #001 – July 28th, 2021

Dear Prospective Bidders;

See below for questions and answers on the proposal received to date:

1. How tall are the poles supposed to be?
 - a. **Poles shall be 16 FT tall**
2. What are the poles supposed to be made from? Steel/aluminum/fiberglass?
 - a. **Bidder can specify. City requests 4" diameter round poles in matte black.**
3. Are the conduit & wire sizes at the contractor's discretion?
 - a. **Yes**
4. Is the wiring supposed to be included in the conduit unit prices?
 - a. **Wiring is incidental to the other items, and will not be paid separately.**
5. Are the lights controlled only by photocell or is a time clock required as well?
 - a. **Photocell and time clock are both required.**
6. Is the city arranging, coordinating and paying for the electric utility to connect to the control panel?
 - a. **Contractor shall coordinate with Consumers Energy for the location and details of the service. City will pay Consumers Energy directly for the cost to connect.**
7. Are any road permits, photometric reviews or planning commission reviews anticipated?
 - a. **All roads are owned by the City of Muskegon and no permits will be required. No additional photometric reviews or planning commission reviews are anticipated.**
8. Will a bid bond or PLM bonding be required?
 - a. **No bonding is required**
9. Are Davis/Bacon wages required?
 - a. **No, however firms proposing a prevailing wage will be incentivized in accordance with the city purchasing policy. Bidders proposing a prevailing wage can be awarded the contract if within 1% of the lower bidder that is not paying prevailing wage.**

Sincerely,

Leo Evans
DPW Director
City of Muskegon